

5. **Fire Extinguishers:** Fire extinguishers shall have been serviced within 1 year, having a tag affixed and shall be visible and accessible at all times. Fire extinguishers shall have a minimum rating of 2A-10BC. .
6. **Liquid and Gas Fueled Vehicle & Equipment Display:** All vehicles displayed inside a building of public assembly shall have their batteries disconnected and fuel caps locked or sealed with duct tape (to prevent escape of vapors). No vehicle shall be fueled or de-fueled inside of such buildings, and shall not exceed one quarter of the tank capacity or 5 gallons whichever is less. All vehicles shall be inspected for leaks. All vehicles containing propane tanks shall remove the propane tanks and/or their 10% valves. A means of identifying vehicles meeting all Fire Department requirements shall be affixed by show management.
7. **Propane and Flammable Gases:** No storage of propane or flammable gases is allowed in any tent, canopy or building of public assembly. Liquid propane gasses shall have a maximum of 16 ounces per canister for hand held flame and **a permit is required.**
8. **Tents, Tarps and Awnings:** All tents, tarps and awnings shall be made from material which is not flammable or is treated and maintained in a flame retardant manner. Documentation of Certification is required. Covering of displays with non-approved tarps or plastics **after business hours** is approved. All non-approved tarps or plastic shall be removed prior to opening a building or business to the public.

